

PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**CERTIFICATE**No. 158Date 10.04.2026

It is certified that an inspection team headed by M. KIRAD (Name of Officers with designation) from XEN, PHED DD-II Jodhpur (Name of Department/Office) inspected the EURO INTERNATIONAL SCHOOL, UCHIYARDA, JODHPUR (Name & Address of the School) on 07/04/26 and on the basis of Water Test Report (Attached) bearing no. 596 dated 23/02/26 of PHED REGIONAL LABORATORY, JODHPUR (PHED Lab) certified that the Euro International School (Name of School) found that the Euro Int. School Uchiyarda Jodhpur (Name of School) has safe drinking water facilities for the students and members of staff of the Institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 01 (one year)

Signature with Seal : [Signature]Name : M. KIRADDesignation : XEN, PHED DD-IIName & Address of the Office/ Department : New Jaipur Highway, Uchiyarda, Jodhpur

To

Euro International School,
New Jaipur Highway, Uchiyarda,
Jodhpur

Note : The certificate is to be issued by authorized officer / PHED Lab/ Local Bodies .

The Executive Engineer
PHED Rural II
Jodhpur

TA
AL
07/4/26

Subject: Request for Issuance of Certificate for Safe Drinking Water

Respected Sir,

With due respect, I humbly request you to kindly issue the certificate regarding the availability of safe drinking water supply at Euro International School Jodhpur.

I further request you to please include the following details in the certificate:

1. Latest chemical parameters of the drinking water.
2. Certificate in the prescribed school format.

I shall be highly obliged for your kind cooperation and prompt action in this matter.

Thanking you in anticipation.

Yours sincerely,

Principal

Madhulika

Euro International School, Jodhpur

PRINCIPAL
Euro International School
Uchiyada, Jodhpur (Raj.)



OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT,
REGIONAL LABORATORY-JODHPUR (RAJ.)

Email:- phedregionallabjodhpur@gmail.com

No. Lab/Tech/Chm./2025-2026/ 598

Date: 23-02-2026

TEST REPORT OF THE CHEMICAL EXAMINATION OF WATER

To,
PRINCIPAL
EURO INTERNATIONAL SCHOOL
New Jaipur Highway Uchiyada
JODHPUR

**SAMPLE WAS NOT COLLECTED
BY THE LABORATORY**

District: JODHPUR
Sample Taker: -

Reference: 116

Dated: 19.02.2026

Date of Receipt	20.02.2026
Date of Collection	20.02.2026
Date of Examination	23.02.2026
Source Type	Water Tank
Source Location	Not for Legal Purpose New Jaipur Highway Uchiyada
City	JODHPUR
Lab Sample No.	PC-96

S. No.	Characteristics	Permissible Value as per BIS 10500/2012 Drinking Water Standards		Test Results
		Desirable Limit	Permissible Limit in absence of alternate Source	
1	pH @ 25 °C	6.5 to 8.5	No relaxation	7.75
2	Turbidity(NTU)	1	5	0.10
3	Colour	5	15	0.10
4	Odour	Agreeable	Agreeable	Agreeable
5	Temperature	—	—	-
6	Total Alkalinity (as CaCO ₃)	200	600	80
7	Total Hardness (as CaCO ₃)	200	600	108
8	Calcium (as Ca ⁺⁺)	75	200	30.40
9	Magnesium (as Mg ⁺⁺)	30	100	7.68
10	Chloride (as Cl)	250	1000	28
11	Sulphate(as SO ₄)	200	400	-
12	Nitrates (as NO ₃)	45	No relaxation	4.63
13	Fluoride (as F)	1	1.5	0.10
14	Total Dissolved Solids (TDS)	500	2000	190

Remark:-

Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur

No. Lab/Tech/Chm./2025-2026/

Date :

Copy to:

1. The Chief Chemist, Public Health Engineering Department-Rajasthan, Jaipur.

Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur

